

深圳市华旭达精密电路科技有限公司

废水处理站运行记录表

日期: 2019.3.29

电表: 326.8 - 326.6

天气: 阴

时间	总排口检测记录							加药记录								
	流量计	pH值	TOC	COD	总铜	氨氮	总磷	FeSO ₄	CaO	H ₂ SO ₄	NaOH	NaS	NaClO _{10.5} %漂白水	PAM	其它	
8:00																
9:00	70437	7.6		16.5	0.0233	1.65	0.088									
10:00		7.5		31.1	0.0255	1.69	0.091	25	25							
11:00	70472	7.5						25	25							
12:00				38.1	0.0241	1.71	0.092									
13:00																
14:00	70472	7.7		39.0	0.0232	1.74	0.090	25	25							
15:00		7.6						25								
16:00		7.6		38.6	0.0282	1.71	0.089	25	25							
17:00	70533	7.5								25						
18:00																
19:00																
小计/平均	96 m ³	7.5		38.6	0.0287	1.71	0.089	125	50	25			260-50 =190			
显影/脱膜 废水																
污泥	压泥机运行:	1#							2# 8:00 - 17:30							
	污泥产生量:															
维修记录																
备注	上月基数: 70437 立方米 中午 11:45 分 索奥 取样.															

操作员:

深圳市华旭达精密电路科技有限公司

废水处理站运行记录表

日期: 2019.3.2

电表: 326.8 - 327.4

天气: 多云-阵雨

时间	总排口检测记录							加药记录							
	流量计	pH值	TOC	COD	总铜	氨氮	总磷	FeSO ₄	CaO	H ₂ SO ₄	NaOH	NaS	NaClO _{10.5} %漂白水	PAM	其它
8:00				25.6	0.1629	2.15	0.094				25	25			
9:00	70533	7.3						25	25						
10:00		7.2		39.3	0.01614	2.25	0.094	25	25						
11:00	70571	7.2						25	25						
12:00				39.8	0.1350	2.10	0.091								
13:00	70571	7.4							25						
14:00		7.3		38.6	0.0416	2.09	0.090	25							
15:00		7.3						25	25						
16:00		7.2		37.4	0.0412	2.03	0.090	25							
17:00	70630	7.2						25							
18:00															
19:00															
小计/平均	97m ³	7.2		37.4	0.0412	2.03	0.090	150	100		25	25	170-45 214		
显影/脱膜 废水															
污泥	压泥机运行:	1#							2# 8:00 - 17:30						
	污泥产生量:														
维修记录	气动隔膜泵														
备注															

操作员:

肖嘉洋

深圳市华旭达精密电路科技有限公司

废水处理站运行记录表

日期: 2019.3.3

电表: 327.6 - 328.2

天气: 雨

时间	总排口检测记录							加药记录								
	流量计	pH值	TOC	COD	总铜	氨氮	总磷	FeSO ₄	CaO	H ₂ SO ₄	NaOH	NaS	NaClO _{10.5} %漂白水	PAM	其它	
8:00				14.2	0.0790	2.48	0.091			75						
9:00																
10:00	70631	7.4		13.7	0.0803	2.50	0.089	25	25				30			
11:00	70654	5.3						25+25	25							
12:00				21.2	0.0762	2.23	0.090									
13:00																
14:00	70656	7.40 7.30		20.1	0.0400	2.98	0.097	25	25	25						
15:00								25	25							
16:00		7.2		20.1		2.02	0.091	25	25							
17:00								25	25							
18:00	70724	7.1														
19:00																
小计/平均	90m ³	7.1		20.1	0.0400	2.02	0.091	175	125	100			75-75 =100			
显影/脱膜 废水	7m ³															
污泥	压泥机运行:	1#							2# 10:00 - 17:30							
	污泥产生量:								320kg							
维修记录																
备注																

操作员:

小胡

深圳市华旭达精密电路科技有限公司

废水处理站运行记录表

日期: 2019.3.4

电表: 328.4 - 329.0

天气: 多云

时间	总排口检测记录							加药记录							
	流量计	pH值	TOC	COD	总铜	氨氮	总磷	FeSO ₄	CaO	H ₂ SO ₄	NaOH	NaS	NaClO _{10.5} 漂白水	PAM	其它
8:00				11.8	缺	2.10	0.091	25			125				
9:00	70721	7.4			2.21										
10:00				19.1	0.0251	2.12	0.091	25	25						
11:00	70754	7.2						25							
12:00				19.3	0.033	2.09	0.093								
13:00	70754	7.5													
14:00		7.3		19.7	0.0317	2.17	0.089	25	25						
15:00		7.3						25							
16:00		7.3		19.8	0.0292	2.25	0.092	25	25						
17:00	70825	7.2						25	25	25					
18:00															
19:00															
小计/平均	104m ³	7.3		19.8	0.0292	2.25	0.092	175	100	25	125		1000 270		
显影/脱膜 废水															
污泥	压泥机运行:	1#								2# 8:00 - 17:30					
	污泥产生量:														
维修记录															
备注															

操作员: 李景华

深圳市华旭达精密电路科技有限公司

废水处理站运行记录表

日期: 2019.3.5

电表: 329.2 - 330.0

天气: 中雨

时间	总排口检测记录							加药记录								
	流量计	pH值	TOC	COD	总铜	氨氮	总磷	FeSO ₄	CaO	H ₂ SO ₄	NaOH	NaS	NaClO _{10.5} %漂白水	PAM	其它	
8:00				12.1	0.0243	2.44	0.088									
9:00	70825	7.4							25							
10:00		7.3		21.3	0.0230	4.37	0.175	25								
11:00	70868	7.2						25								
12:00				30.0	0.0251	4.67	0.284									
13:00	70868	7.4						25	25			25				
14:00		7.3		28.4	0.0266	4.88	0.279	25								
15:00								25	25							
16:00		7.3		27.0	0.0275	4.80	0.273	25	25							
17:00		7.3						25	25					20		
18:00		7.1		16.6	0.0288	4.70	0.266	25								
19:00	70920	7.4														
小计/平均	145	7.4		16.6	0.0288	4.70	0.266	200	125			25	20-30 20	20		
显影/脱膜 废水																
污泥	压泥机运行:		1# 14:00 - 18:00							2# 10:00 - 18:00						
	污泥产生量:															
维修记录																
备注																

操作员:

甘克强

深圳市华旭达精密电路科技有限公司

54

废水处理站运行记录表

日期: 2019.3.6

电表: 330.2 - 330.9

天气: 阴

时间	总排口检测记录							加药记录							
	流量计	pH值	TOC	COD	总铜	氨氮	总磷	FeSO ₄	CaO	H ₂ SO ₄	NaOH	NaS	NaClO _{10.5} %漂白水	PAM	其它
8:00		7.2		7.2	0.0191	4.11	0.223			25					
9:00	70970	7.5						25	25				2043		
10:00		7.4		24.4	0.0191	4.14	0.21	25+25	25						
11:00	71020	7.4						25	25						
12:00				38.2	0.0174	4.14	0.198								
13:00															
14:00	71020	7.5		37.0	0.0147	4.11	0.193	25	25	50					
15:00		7.5						25	25						
16:00		7.4		37.7	0.0149	4.03	0.185	25	25						
17:00		7.3						25			25				
18:00	71091	7.3						25							
19:00															
小计/平均	121 m ³	7.3		37.7		4.05	0.180	225	150	125	25		80.60 =20		
显影/脱膜 废水	7 m ³														
污泥	压泥机运行:	1# 10:00 - 17:30								2# 8:00 - 16:00					
	污泥产生量:	260 kg													
维修记录															
备注															

操作员:

李